

Andes Central School

Lead in water exceedances for first draw samples taken on 9/18/2016.

	Location/Sample ID	Lead level in parts per billion (action level 15 ppb)
1	5-athletic restroom	757.0
2	6-girls locker L	213.0
3	7-girls locker R	87.8
4	8-boys locker L	20.1
5	9-boys locker R	53.6

Sampling conducted by Josh Reiss and Phyllis Kochersberger

Analysis conducted by Microbac Laboratories